

W7350A1000 CD Installation and Software Update

INSTALLATION INSTRUCTIONS

NOTE: Honeywell recommends that before you install the WebStat in a customer site, you load the latest release of the software on to the WebStat platform.

Please use the enclosed CD-ROM, part number #50030935-001, to save the software file update v01.02.03 to your local PC hard drive or desktop. Alternatively, you can download the latest WebStat software update from <http://customer.honeywell.com/Business/Cultures/en-US/Products/Applications+and+Downloads/>.

The latest update, v01.02.03, provides performance enhancements as well as compatibility for Internet Explorer v7.0. The performance enhancements allow your controller to more effectively execute and update the firmware memory operations. It is strongly advised to load the v01.02.03 update to ensure that proper performance is achieved over the duration of the product installment period.

After the software file is loaded to the PC hard drive or desktop, the file can be uploaded into the WebStat controller using the following directions:

INSTALLATION PROCESS

1. Download the update software to your local PCs from the CD-ROM or from the above <http://> link and save it to a known location on your hard drive.
2. Connect to the WebStat per the instructions you received with the product regarding configuring the network settings. See the Quick Start Guide 63-2657 for instructions.
3. Open your browser interface and navigate to the WebStat login screen. See the Quick Start Guide 63-2657 for instructions.
4. Once you have logged in, navigate to the SETUP screen and GENERAL TAB.
5. Make backup of your configuration by pressing the BACKUP CONFIGURATION button at the top of this screen and save the file to your local hard drive.
6. Then from the item labeled Software Update Package on the same screen, select the upgrade file v01.02.03 from your local hard drive on your PC using the Browse Button.
7. Press the Upload Button to install the software. The WebStat will automatically reboot during this process.
8. After 5 to 8 minutes, the WebStat should have rebooted and you can now access the system again.
9. Note that the current version of software for WebStat is shown in the upper left hand corner, as seen in Fig. 1.



The screenshot displays the Honeywell WebStat software interface. At the top, the 'WebStat' logo is on the left, and the date 'Dec 14, 2007 12:16pm' along with 'Help' and 'Logout' links are on the right. A navigation bar includes tabs for Overview, Floor Plans, Schedules, Alarms, Trends, Users, Thermostats, and System. Below this, it shows 'Logged in as Honeywell Contractor' and 'Outside Temperature: 0 °F | Weather Underground'. A secondary navigation bar has tabs for General, Email Setup, Network Setup, and Login Page Setup. The main content area is divided into several sections:

- WebStat™ Information:** Copyright © 2006, Version 01.02.03, Nov 20 2007.
- Software Update Package:** A section with a 'Browse...' button, an 'Upload' button, and three buttons below: 'Backup Configuration', 'Restore Configuration', and 'Reboot WebStat'.
- Time and Date Settings:** Includes fields for Time (12 : 16), Date (12/14/2007), Time Server Address (time-a.nist.gov), and Time Zone (US/Eastern (-5/-4)). It also has checkboxes for 'Use Internet Time Server' and 'Webstat is Network Time Master', each with a 'Sync Now' button. Footnotes explain that changing the system clock may invalidate the session and that changing the time zone requires rebooting.
- Engineering units:** Radio buttons for 'US English' (selected) and 'Metric'.
- Local Weather And Outdoor Air Temperature:** A dropdown menu for 'Select a thermostat to display outside temperature' (RTU_5 Third floor), and input fields for 'Enter external link URL' (http://www.weatherunderground.com/) and 'Enter external link title' (Weather Underground).

 A 'Save' button is located at the bottom right of the interface.

Fig. 1. WebStat software version.

By using this Honeywell literature, you agree that Honeywell will have no liability for any damages arising out of your use or modification to, the literature. You will defend and indemnify Honeywell, its affiliates and subsidiaries, from and against any liability, cost, or damages, including attorneys' fees, arising out of, or resulting from, any modification to the literature by you.

Automation and Control Solutions

Honeywell International Inc.
 1985 Douglas Drive North
 Golden Valley, MN 55422
 customer.honeywell.com

Honeywell Limited-Honeywell Limitée
 35 Dynamic Drive
 Toronto, Ontario M1V 4Z9

