

Honeywell

NOTICE

The alarm terminal on this S87 is a 3/16 in. male quick-connect instead of the 1/4 in. female quick-connect shown in the accompanying instructions, form 68-0039—1.

Addendum to form 68-0039—1.